

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Dr. R.B Yadav ,Superintendent from C.H.C,CHOLAPUR,VNS (Name of Officers with designation) inspected the **SUNBEAM SCHOOL CHOLAPUR** at Lakhanpur,Post-Cholapur District-Varanasi,Uttar Pradesh, Pin Chode-221101 (Name & Address of the school) on 15/05/2026 (date of inspection) on the basis of Water test Report (Attached) bearing no. CVNS/MAY26/00105 dated 11/05/2026 of Regional Water Analysis Laboratory U.P Jal Nigam (Rural) Varanasi (PHED Lab) certified that the **SUNBEAM SCHOOL CHOLAPUR** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 20/05/2027

Signature with Seal:

Name

Designation

R.B. Yadav
अधीक्षक
साठ स्या. केन्द्र
चोलापुर, वाराणसी

To

Name & Address of the Office / Department :

Principal,
Sunbeam School Cholapur
at Lakhanpur Post-Cholapur
Dist. Varanasi Uttar Pradesh
Pin.221101

Manish Chandra
Principal
Sunbeam School
Cholapur

SEEMA
Principal
Sunbeam School, Cholapur
Varanasi

School Code:-71392

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

AN NO: 2132578

Water Analysis Report



Regional Water Analysis Laboratory

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005

Report No.: C/VNS/MAY26/00105		Date: 11.05.2026	No. of Pages: 1
Customer Details			
Office Name and Address		Sunbeam School, Cholapur	
Ref. Letter No. & Date		SBS/CLP/2026/0119 Date: 29.04.2026	
Basic Details of Sample			
District	Varanasi	Block	Cholapur
Gram Panchayat	Lakhanpur	Village	Lakhanpur
Habitation	NA	Location	School Campus, Cholapur, Varanasi
Water Source	Submersible	Sample Code	VNS/MAY26/00105
Quantity of Sample	1000 ml (Normal)	Sampling date	06.05.2026
Sample Received Date	06.05.2026	S. collected by	Mr Mahadev Maurya
Sampling Method Used	NA	Sample Depositor	Mr Mahadev Maurya
Analysis Start Date	07.05.2026	Analysis Completion date	07.05.2026

Temperature-26.2°C, Humidity- 61%

Test Result					
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.48	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.51	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	523.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	16.02	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	390.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	312.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	48.12	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	46.08	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	13.27	200	400	APHA 24rd Edition -4500 SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	7.27	45	No relaxation	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.82	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method): 2023
12	Iron (as Fe), mg/l	0.16	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023

BDL-Below Detection Limit, NA- Not Analysed

- Note:**
1. This certificate refers only to the particular sample(s) submitted for analysis.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
 5. Parameters above Permissible Limit are written in bold.
 6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 7. Sample is not Collected by Lab.
 8. Source is not verified by the Lab

Mavish Chandel
Manager
Sunbeam School
Cholapur

ABHAY KUMAR PANDEY
(Report prepared by)

SREEMA
Principal
Sunbeam School Cholapur
Varanasi
Sch. No. 11/202
Aff. No. 11/202

(Report Authorized & Reviewed by)

Laboratory Contact detail:

Email: aroupjn@gmail.com

Mobile No.:8400202287

*****END OF THE ANALYSIS REPORT*****

